THE MYSORE ECONOMIC CONFERENCE.

Official Memorandum No. 530-35, dated 28—29th November 1913:

In accordance with Government Order No. G. 1294-342—G. M. 69-13-3, dated 12th August 1913, amending Rule 7 of the Revised Rules for the constitution of the Economic Conference published under Government Order No. G. 4058-109—G. M. 55-12-109, dated 25th January 1913, the following nine gentlemen are appointed as members of the Hassan District Committee for the year 1913-14:—

Official Members.

(1) The District Medical and Sanitary Officer, Hassan.
(2) The District Excise Officer, Hassan.
(3) The Head Master, Hassan High School.

Non-official Members.

(4) Mr. G. K. Padmarajiah, Sravanabelagola, Channarayapatna Taluk.
(5) „ M. Venkoba Rao, retired Amrut Mahal Daroga, Hole-Narsipur.
(6) „ M. H. Harianna of Dodmetikurke, Arsikere Taluk.
(7) „ Mohamad Raza, retired Assistant Commissioner, Hassan.
(8) „ B. Puttusami Shetti of Basvapatna, Arkalgud Taluk.
(9) „ Chikkannagowda, Patel of Halebid, Belur Taluk.

By Order,
C. S. BALASUNDARAM IYER,
Secretary.

To—The Deputy Commissioner and President, District Committee, Hassan.
The Secretaries of the Central Committees.
The Comptroller, Mysore Government.
The Compiler, *Mysore Gazette.*

SANITARY.

PROCEEDINGS OF THE CENTRAL SANITARY BOARD IN MYSORE.

READ—

Letter No. 630—Ml. 111-12, dated the 5th July 1913, from the Secretary to the Government of His Highness the Maharaja of Mysore, General and Revenue Departments, forwarding for the opinion of the Board a memorandum drawn up by the Superintending Engineer, Southern Circle, on the subject of improvement of Water-supply to the Kolar Town.

Resolution No. 2, Bangalore, dated 26th November 1913.

The scheme recommended involves a capital outlay of Rs. 28,000 and an annual recurring charge of Rs. 1,100 and provides for the following improvements:—

(i) Converting the open channel from the Ammerhalli tank to the Distribution Reservoir into a covered masonry channel, at an estimated cost of Rs. 15,000.

(ii) Constructing 3 masonry basins each large enough to hold three days' supply, one for filling, another for settling and the third for supplying clarified water, the estimated cost being Rs. 5,000, and,

(iii) Replacing the existing cement pipes (leading from the reservoir about one mile from the outskirts of the town) by 6" iron pipes at an estimated cost of Rs. 8,000.

2. The Board are agreed that the scheme recommended is sound and may be adopted. In view, however, of the limited resources of the Municipality the items of work detailed under (ii) and (iii) may be carried out as a first instalment of the improvement, the Municipality endeavouring to find funds, by levy of a water-tax, if necessary, in order to gradually extend the pipe line right up to the tank.

3. Resolved that the above views be submitted to Government.

P. S. ACHYUTA RAO,
President, Central Sanitary Board.